

NAME ROCK FALLS, CITY OF  
ADDRESS 603 W 10TH ST  
ROCK FALLS, IL 61071

IL0078301  
PERMIT NUMBER

INF-L  
DISCHARGE NUMBER

MAJOR (SUBR 01)  
INFLUENT MONITORING AND REPORTING  
INFLUENT STRUCTURE

FACILITY LOCATION ROCK FALLS, CITY OF  
101 CLEARWATER DR.  
ROCK FALLS, IL 61071


MONITORING PERIOD  
FROM 01 01 19 TO 01 31 19

\*\*\* NO DISCHARGE  \*\*\*

ATTN: WILLIAM WESCOTT

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
BOD, 5-Day (20 DEG. C) 00310 1 0 RAW SEW / INFLUENT	SAMPLE MEASUREMENT	*****	*****	( 26)	*****	76	*****	( 19)	00	250	CP
	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	Req. Mon. MO AVG	*****	MG/L		3 DAYS WEEK	COMPOS
Solids, Total Suspended 00530 1 0 Raw Sew / Influent	SAMPLE MEASUREMENT	*****	*****	( 26)	*****	213	*****	( 19)	00	250	CP
	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	Req. Mon. MO AVG	*****	MG/L		3 DAYS WEEK	COMPOS
Flow, In Conduit or Thru Treatment Plant 50050 1 0 RAW SEW / INFLUENT	SAMPLE MEASUREMENT	1.765	1.870	( 03)	*****	*****	*****		00	105	CN
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	**** ****		CONTINUOUS	CONTIN
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER William Wescott Mayor	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			815 622-1125	19 02 05	AREA CODE	NUMBER	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME ROCK FALLS, CITY OF  
 ADDRESS 603 W 10TH ST  
 ROCK FALLS, IL 61071

FACILITY LOCATION ROCK FALLS, CITY OF  
 101 CLEARWATER DR.  
 ROCK FALLS, IL 61071

ATTN: WILLIAM WESCOTT

IL0078301  
 PERMIT NUMBER

001-0  
 DISCHARGE NUMBER

DMR Mailing ZIP CODE: 61071  
 MAJOR (SUBR 01)  
 STP OUTFALL  
 EXTERNAL OUTFALL

MONITORING PERIOD					
MM	DD	YYYY	MM	DD	YYYY
01	01	19	01	31	19

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, Dissolved (DO) 00300 1 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		9.1	8.9	8.5	(19)	00	250	GR
	PERMIT REQUIREMENT	*****	*****	**** ****	5.5 MO AV MN	4.0 MN WK AV	3.5 DAILY MN	MG/L		3 DAYS WEEK	GRAB
PH 00400 1 0 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		7.7	*****	8.1	(12)	00	250	GR
	PERMIT REQUIREMENT	*****	*****	**** ****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		3 DAYS WEEK	GRAB
Solids, Total Suspended 00530 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	19	40	(26)	*****	1	3	(19)	00	250	CP
	PERMIT REQUIREMENT	751 MO AVG	1501 DAILY MX	LBS/DY	*****	12 MO AVG	24 DAILY MX	MG/L		3 DAYS WEEK	COMPOS
NITROGEN, TOTAL 00600 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	9.10	*****	(19)	00	285	CP
	PERMIT REQUIREMENT	*****	*****	**** ****	*****	Req. Mon. MO AVG	*****	MG/L		MONTHL Y	COMPOS
Nitrogen, Ammonia Total (as N) 00610 1 3 Effluent Gross Value	SAMPLE MEASUREMENT	0	0	(26)	*****	0.009	0.030	(19)	00	250	CP
	PERMIT REQUIREMENT	250 MO AVG	726 DAILY MX	LBS/DY	*****	4.0 MO AVG	11.6 DAILY MX	MG/L		3 DAYS WEEK	COMPOS
Total (as N) 00610 8 6 Other Treatment, Process Complete	SAMPLE MEASUREMENT	0.1	*****	(26)	*****	0.0	*****	(19)	00	250	CP
	PERMIT REQUIREMENT	626 WK AV	*****	LBS/DY	*****	10.0 WK AV	*****	MG/L		3 DAYS WEEK	COMPOS
PHOSPHORUS, TOTAL (as P) 00665 1 0 Effluent Gross Value	SAMPLE MEASUREMENT	3.0	*****	(26)	*****	0.23	*****	(19)	00	250	CP
	PERMIT REQUIREMENT	63 MO AVG	*****	LBS/DY	*****	1 MO AVG	*****	MG/L		3 DAYS WEEK	COMPOS
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.						TELEPHONE		DATE		
William Wescott Mayor							815 622-1125		19	02	05
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME ROCK FALLS, CITY OF  
ADDRESS 603 W 10TH ST  
ROCK FALLS, IL 61071

IL0078301  
PERMIT NUMBER

001-0  
DISCHARGE NUMBER

MAJOR  
(SUBR 01)  
STP OUTFALL  
EXTERNAL OUTFALL

FACILITY LOCATION ROCK FALLS, CITY OF  
101 CLEARWATER DR.  
ROCK FALLS, IL 61071

MONITORING PERIOD  
MM DD YYYY TO MM DD YYYY  
01 01 19 TO 01 31 19

ATTN: WILLIAM WESCOTT

\*\*\*NO DISCHARGE \*\*\*

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	1.561	1.670	(03)	*****	*****	*****		00	105	CN
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	****		CONTINUOUS	CONTIN
Chlorine, Total Residual 50060 1 1 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0	(19)	00	500	GR
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	.05 DAILY MX	MG/L		Chlorination/	GRAB
BOD, Carbonaceous 05 DAY, 20C 80082 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	17	23	(26)	*****	1	2	(19)	00	250	CP
	PERMIT REQUIREMENT	626 MO AVG	1251 DAILY MX	LBS/DY	*****	10 MO AVG	20 DAILY MX	MG/L		3 DAYS WEEK	COMPOS
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.					TELEPHONE			DATE		
William Wescott Mayor						815 622-1125			19	02	05
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)