

NAME ROCK FALLS, CITY OF
 ADDRESS 603 W 10TH ST
 ROCK FALLS, IL 61071

 FACILITY ROCK FALLS, CITY OF
 LOCATION 101 CLEARWATER DR.
 ROCK FALLS, IL 61071

ATTN: WILLIAM WESCOTT

 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

 IL0078301
 PERMIT NUMBER

 INF-L
 DISCHARGE NUMBER

MONITORING PERIOD							
MM			DD			YYYY	
FROM	12	01	20	TO	12	31	20

DMR Mailing ZIP CODE: 61071

MAJOR

(SUBR 01)


INFLUENT MONITORING AND REPORTING

INFLUENT STRUCTURE

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
BOD, 5-Day (20 DEG. C) 00310 1 0 RAW SEW / INFLUENT	SAMPLE MEASUREMENT	*****	*****	(26)	*****	82	*****	(19)	00	250	CP
	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	Req. Mon. MO AVG	*****	MG/L		3 DAYS WEEK	COMPOS
Solids, Total Suspended 00530 1 0 Raw Sew / Influent	SAMPLE MEASUREMENT	*****	*****	(26)	*****	121	*****	(19)	00	250	CP
	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	Req. Mon. MO AVG	*****	MG/L		3 DAYS WEEK	COMPOS
Flow, In Conduit or Thru Treatment Plant 50050 1 0 RAW SEW / INFLUENT	SAMPLE MEASUREMENT	1.342	1.540	(03)	*****	*****	*****		00	105	CN
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	**** ****		CONTIN UOUS	CONTIN
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
William Wescott Mayor			815 622-1125	21	01	05
TYPED OR PRINTED			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME ROCK FALLS, CITY OF
 ADDRESS 603 W 10TH ST
 ROCK FALLS, IL 61071

 FACILITY ROCK FALLS, CITY OF
 LOCATION 101 CLEARWATER DR.
 ROCK FALLS, IL 61071

ATTN: WILLIAM WESCOTT

 IL0078301
 PERMIT NUMBER
 001-0
 DISCHARGE NUMBER

 MONITORING PERIOD
 FROM MM DD YYYY TO MM DD YYYY
 12 01 20 12 31 20

DMR Mailing ZIP CODE: 61071

MAJOR

(SUBR 01)

STP OUTFALL

EXTERNAL OUTFALL

 *** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, Dissolved (DO) 00300 1 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		8.3	8.1	7.8	(19)	00	250	GR
	PERMIT REQUIREMENT	*****	*****	**** ****	5.5 MO AV MN	4.0 MN WK AV	3.5 DAILY MN	MG/L		3 DAYS WEEK	GRAB
PH	SAMPLE MEASUREMENT	*****	*****		7.8	*****	8.3	(12)	00	250	GR
00400 1 0 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	**** ****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		3 DAYS WEEK	GRAB
Solids, Total Suspended 00530 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	19	58	(26)	*****	2	6	(19)	00	250	CP
	PERMIT REQUIREMENT	751 MO AVG	1501 DAILY MX	LBS/DY	*****	12 MO AVG	24 DAILY MX	MG/L		3 DAYS WEEK	COMPOS
NITROGEN, TOTAL	SAMPLE MEASUREMENT	*****	*****		*****	6.50	*****	(19)	00	285	CP
00600 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**** ****	*****	Req. Mon. MO AVG	*****	MG/L		MONTHLY	COMPOS
Nitrogen, Ammonia Total (as N) 00610 1 3 Effluent Gross Value	SAMPLE MEASUREMENT	0	1	(26)	*****	0.027	0.080	(19)	00	250	CP
	PERMIT REQUIREMENT	250 MO AVG	726 DAILY MX	LBS/DY	*****	4.0 MO AVG	11.6 DAILY MX	MG/L		3 DAYS WEEK	COMPOS
Total (as N) 00610 8 6 Other Treatment, Process Complete	SAMPLE MEASUREMENT	0.3	*****	(26)	*****	0.1	*****	(19)	00	250	CP
	PERMIT REQUIREMENT	626 WK AV	*****	LBS/DY	*****	10.0 WK AV	*****	MG/L		3 DAYS WEEK	COMPOS
PHOSPHORUS, TOTAL (as P)	SAMPLE MEASUREMENT	0.8	*****	(26)	*****	0.08	*****	(19)	00	250	CP
00665 1 0 Effluent Gross Value	PERMIT REQUIREMENT	63 MO AVG	*****	LBS/DY	*****	1 MO AVG	*****	MG/L		3 DAYS WEEK	COMPOS
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.				TELEPHONE		DATE			
William Wescott Mayor						815 622-1125		21	01	05	
TYPED OR PRINTED						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME ROCK FALLS, CITY OF
ADDRESS 603 W 10TH ST
ROCK FALLS, IL 61071

FACILITY ROCK FALLS, CITY OF
LOCATION 101 CLEARWATER DR.
ROCK FALLS, IL 61071

ATTN: WILLIAM WESCOTT

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

IL0078301
PERMIT NUMBER

001-0
DISCHARGE NUMBER

MONITORING PERIOD					
MM	DD	YYYY	MM	DD	YYYY
12	01	20	12	31	20

FROM

TO

DMR Mailing ZIP CODE: 61071

MAJOR

(SUBR 01)

STP OUTFALL

EXTERNAL OUTFALL

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	1.167	1.440	(03)	*****	*****	*****		00	105	CN
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	**** ****		CONTIN UOUS	CONTIN
Chlorine, Total Residual 50060 1 1 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0	(19)	00	500	GR
	PERMIT REQUIREMENT	*****	*****	**** ****	*****	*****	.05 DAILY MX	MG/L		Chlorinati on/	GRAB
BOD, Carbonaceous 05 DAY, 20C 80082 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	11	22	(26)	*****	1	2	(19)	00	250	CP
	PERMIT REQUIREMENT	626 MO AVG	1251 DAILY MX	LBS/DY	*****	10 MO AVG	20 DAILY MX	MG/L		3 DAYS WEEK	COMPOS
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER William Wescott Mayor	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		815	622-1125	21	01	05
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)