

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME ROCK FALLS, CITY OF
 ADDRESS 603 W 10TH ST
 ROCK FALLS, IL 61071
 FACILITY ROCK FALLS, CITY OF
 LOCATION 101 CLEARWATER DR.
 ROCK FALLS, IL 61071
 ATTN: WILLIAM WESCOTT

NATIONAL POLLUTANT ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

IL0078301
 PERMIT NUMBER

INF-L
 DISCHARGE NUMBER


DMR Mailing ZIP CODE: 61071
 MAJOR (SUBR 01)
 INFLUENT MONITORING AND REPORTING
 INFLUENT STRUCTURE

MONITORING PERIOD					
MM	DD	YYYY	MM	DD	YYYY
03	01	17	03	31	17

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
BOD, 5-Day (20 DEG. C) 00310 1 0 RAW SEW / INFLUENT	SAMPLE MEASUREMENT	*****	*****	(26)	*****	89	*****	(19)	00	250	CP
	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	Req. Mon. MO AVG	*****	MG/L		3 DAYS WEEK	COMPOS
Solids, Total Suspended 00530 1 0 Raw Sew / Influent	SAMPLE MEASUREMENT	*****	*****	(26)	*****	131	*****	(19)	00	250	CP
	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	Req. Mon. MO AVG	*****	MG/L		3 DAYS WEEK	COMPOS
Flow, In Conduit or Thru Treatment Plant 50050 1 0 RAW SEW / INFLUENT	SAMPLE MEASUREMENT	1.541	1.770	(03)	*****	*****	*****		00	105	CN
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	**** ****		CONTINUOUS	CONTIN
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER William Wescott Mayor	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME ROCK FALLS, CITY OF
 ADDRESS 603 W 10TH ST
 ROCK FALLS, IL 61071

FACILITY LOCATION ROCK FALLS, CITY OF
 101 CLEARWATER DR.
 ROCK FALLS, IL 61071

ATTN: WILLIAM WESCOTT

IL0078301
 PERMIT NUMBER

001-0
 DISCHARGE NUMBER

DMR Mailing ZIP CODE: 61071
 MAJOR (SUBR 01)
 STP OUTFALL
 EXTERNAL OUTFALL

MONITORING PERIOD					
MM	DD	YYYY	MM	DD	YYYY
03	01	17	03	31	17

FROM

TO

***NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, Dissolved (DO) 00300 1 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		*****	8.4	8.8	(19)	00	250	GR
	PERMIT REQUIREMENT	*****	*****	**** ****	*****	6.0 MN WK AV	5.0 DAILY MN	MG/L		3 DAYS WEEK	GRAB
PH 00400 1 0 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		7.6	*****	8.0	(12)	00	250	GR
	PERMIT REQUIREMENT	*****	*****	**** ****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		3 DAYS WEEK	GRAB
Solids, Total Suspended 00530 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	13	33	(26)	*****	1	3	(19)	00	250	CP
	PERMIT REQUIREMENT	751 MO AVG	1501 DAILY MX	LBS/DY	*****	12 MO AVG	24 DAILY MX	MG/L		3 DAYS WEEK	COMPOS
NITROGEN, TOTAL 00600 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	3.00	*****	(19)	00	285	CP
	PERMIT REQUIREMENT	*****	*****	**** ****	*****	Req. Mon. MO AVG	*****	MG/L		MONTHLY	COMPOS
Nitrogen, Ammonia Total (as N) 00610 1 3 Effluent Gross Value	SAMPLE MEASUREMENT	0	0	(26)	*****	0.017	0.030	(19)	00	250	CP
	PERMIT REQUIREMENT	94 MO AVG	394 DAILY MX	LBS/DY	*****	1.5 MO AVG	6.3 DAILY MX	MG/L		3 DAYS WEEK	COMPOS
Total (as N) 00610 8 6 Other Treatment, Process Complete	SAMPLE MEASUREMENT	0.2	*****	(26)	*****	0.0	*****	(19)	00	250	CP
	PERMIT REQUIREMENT	238 WK AV	*****	LBS/DY	*****	3.8 WK AV	*****	MG/L		3 DAYS WEEK	COMPOS
PHOSPHORUS, TOTAL (as P) 00665 1 0 Effluent Gross Value	SAMPLE MEASUREMENT	1.8	*****	(26)	*****	0.16	*****	(19)	00	250	CP
	PERMIT REQUIREMENT	63 MO AVG	*****	LBS/DY	*****	1 MO AVG	*****	MG/L		3 DAYS WEEK	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

William Wescott
 Mayor

TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Edward J. Co

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

815 622-1125

DATE

17 04 05

AREA CODE

NUMBER

YEAR

MO

DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME ROCK FALLS, CITY OF
ADDRESS 603 W 10TH ST
ROCK FALLS, IL 61071

IL0078301
PERMIT NUMBER

001-0
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 61071
MAJOR (SUBR 01)
STP OUTFALL
EXTERNAL OUTFALL

FACILITY LOCATION ROCK FALLS, CITY OF
101 CLEARWATER DR.
ROCK FALLS, IL 61071


MONITORING PERIOD						
MM	DD	YYYY	TO	MM	DD	YYYY
03	01	17	TO	03	31	17

*** NO DISCHARGE ***

ATTN: WILLIAM WESCOTT

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	1.346	1.620	(03)	*****	*****	*****		00	105	CN
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	****		CONTINUOUS	CONTIN
Chlorine, Total Residual 50060 1 1 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0	(19)	00	500	GR
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	.05 DAILY MX	MG/L		Chlorination/	GRAB
BOD, Carbonaceous 05 DAY, 20C 80082 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	12	22	(26)	*****	1	2	(19)	00	250	CP
	PERMIT REQUIREMENT	626 MO AVG	1251 DAILY MX	LBS/DY	*****	10 MO AVG	20 DAILY MX	MG/L		3 DAYS WEEK	COMPOS
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT								00		
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
William Wescott Mayor			815 622-1125	17	04	05	
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)